





Technical drawing of a circular structure, likely a well or a large container, with a vertical support structure. The drawing includes the following details:

- Top Section:** A circular cross-section with a diameter of  $\varnothing 5.20$ . The center is marked with a crosshair and the value  $293.80$ . The structure is labeled "Jímací okružní vedení FeZn  $\varnothing 8\text{mm}$  uloženo na podpěrách" (Feeding circular FeZn  $\varnothing 8\text{mm}$  laid on supports). The top edge is marked "3xSS".
- Left Grounding:** A grounding point labeled "SZ" (Základový zemnič) and "Vývod č.1" (Outlet No. 1).
- Right Grounding:** A grounding point labeled "SZ" (Základový zemnič) and "Vývod č.2" (Outlet No. 2). Below it, another grounding point is labeled "SZ" (Základový zemnič) and "Vývod č.4" (Outlet No. 4).
- Vertical Support:** A vertical structure supporting the circular top. It has a width of  $1.88$  at the top and  $1.30$  at the bottom. The support structure is labeled "FeZn  $\varnothing 10\text{mm}$ ".
- Dimensions:**
  - Top diameter:  $\varnothing 5.20$
  - Center height:  $293.80$
  - Top support width:  $1.88$
  - Bottom support width:  $1.30$

STŘECHA: PLOCHÁ BETONOVÁ  
JÍMACÍ SOUSTAVA: MŘÍŽOVÁ  
TŘÍDA LPS: III

## LEGENDA

	VEDENÍ LPS
	PODPĚRA VEDENÍ
	ZKUŠEBNÍ SVORKA
	SPOJENÍ VODIČE TYPOVOU SVORKOU
	UZEMŇOVACÍ VEDENÍ

		Telex: +420 541 554 111 Fax: +420 541 211 205		E-mail: info@aquatis.cz <a href="http://www.aquatis.cz">http://www.aquatis.cz</a>	
		AQUATIS a.s. Botanická 834/56, 602 00 Bno			
Zápověď projektant ING. OLDŘICH NEUMAYER, SCS.		Hlavní inženýr projektu ING. OLDŘICH NEUMAYER, SCS.		Vedoucí střediska ING. OLDŘICH NEUMAYER, SCS.	
Vypracoval ING. JŘI WEITER		Kontroloval ING. JŘI MALÝ		Zakázkové číslo 3A15007.32 Y01	
Datum ZŘÍ 2015		Stupeň dokumentace DPS		Název souboru D 1 2 3 3 3 Hromosvod.dwg	
Akce <div style="text-align: center;"> <b>VD VELKÝ RYBNÍK</b>  <b>OBNOVA SPODNÍCH VÝPUSTÍ</b>  <b>D.1.2.3. SO 03 OBJEKT SPODNÍCH VÝPUSTÍ</b>  <b>STAVEBNÍ ELEKTROINSTALACE</b> </div>					
Příloha <div style="text-align: center;"> <b>HROMOSVOD</b> </div>					
Měřítka <div style="text-align: center;"> <b>1:50</b> </div>			Číslo přílohy <div style="text-align: center;"> <b>D.1.2.3.3.</b> </div>		
Objednatel <div style="text-align: center;"> <b>POVOŘÍ LABE, státní podnik</b> </div>					